GDAŃSKI UNIWERSYTET MEDYCZNY
WYDZIAŁ NAUK O ZDROWIU z Oddziałem Pielęgniarstwa i Instytutem Medycyny Morskiej i Tropikalnej
ZAKŁAD TOKSYKOLOGII ŚRODOWISKA
ul. Dębowa 23A
80-204 GDAŃSK
tel./fax 58 349 19 37
e-mail: zts@gumed.edu.pl

322/1028/164/2019

Gdansk, 29-04-2019

HYGIENIC CERTIFICATE No 162/322/164/2019

1. Name of product (material)	**Laminated board - DecoBoard P2** **PN-EN 14322** thickness ranges: 6,0 ÷ 40,0 mm
2. Application	furniture production and interior's decorate
3. Applicant institution	Pfleiderer Polska Spółka z o.o. Strzegomska 42AB St. PL-53-611 Wrocław
4. Manufacturer	Pfleiderer Grajewo Spółka z o.o. Wiórowa 1 St. PL-19-203 Grajewo

5. The product meets the requirements of hygiene on the following conditions:
- the load the material amounts 1,0 m^2/m^3 in relation to the cubage of residential premises, premises intended for permanent stay of patients in health service buildings, children and young people in school buildings and of premises intended for storing food products – hereinafter referred as to the "places of A category",
- load the material amounts 2,0 m^2/m^3 the cubage of premises in public buildings other than those listed above and auxiliary premises in apartments - hereinafter referred as to the "places of B category" according to the Regulation of Minister of Health and Social Care dated on 12th March of 1996.

The certificate does not concern working conditions and occupational hygiene during the assembly of product. Facilities that use the product should be ventilated until the odour disappears.

6. Basis of certificate: applications of OB-RPPD sp. z o.o. BW/452/452/19 dated April 16, 2019, test report number 8300/12/2019 dated April 15, 2019 issued by Research & Development Centre for Wood - Based Panels in Czarna Woda.
Hygienic Class E1.

7. The present certificate shall be changed or voided if either party presents sufficient evidence. Hereby attest will expire 5 years after issuing date or if any changes either in composition or manufacturing technology of the product have been introduced.

KIEROWNIK
Zakładu Toksykologii Środowiska
prof. dr hab. Lidia Wolska